

**ADDENDUM No. 2**  
**Request for Competitive Sealed Proposals (CSP)**  
**19RFP070 Renovations at O’Henry Middle School**

November 28, 2018

**Item 1: HVAC Alarm Shutdown Clarification**

**Item 2: Pre-Bid Conference Sign In Sheet Location**

Item 1:

Paragraph 3 of the Water Source Heat Pump (WSHP) Sequence of Operation on sheet M8.1 applies only to systems over 2000 CFM, i.e. not applicable to WSHPs in this project.

Item 2:

The pre-bid conference sign-in sheet is available for download at

<https://www.austinisd.org/cp/bids#>


and at

<https://planroom.millerids.com/viewdetails.asp?a=editdiscipline&sid=6627&paid=0&prid=1015>

Instructions for submitting questions and viewing Q&A and addenda under new AISD procurement procedures are provided on the project RFP (download at:

<https://planroom.millerids.com/viewdetails.asp?a=editdiscipline&sid=6598&paid=0&prid=1015>

)



**ADDENDUM NUMBER TWO (2)**

AUSTIN INDEPENDENT SCHOOL DISTRICT  
RENOVATIONS AT O'HENRY MIDDLE SCHOOL  
AISD PROJECT NO. 19-0040-OHNR  
SOLICITATION NO. 19CSP070  
November 28<sup>th</sup>, 2018

The Contract Documents and Specifications for the above referenced project are amended and revised as indicated in this Addendum. Any proposal submitted in response to the invitation to the bidders shall be prepared accordingly. Receipt of Addendum is to be acknowledged on the "Bid Form".

**ITEM #1, HVAC Fire Alarm Shutdown Clarification**

- A. Paragraph 3 of the Water Source Heat Pump (WSHP) Sequence of Operation on sheet M8.1 applies only to systems over 2000 CFM, i.e. **not applicable to WSHPs in this project.**

**ITEM #2, Pre-bid Conference Sign-in Sheet Location**

- A. The pre-bid conference sign-in sheet is available for download at <https://www.austinisd.org/cp/bids#> and at <https://planroom.millerids.com/viewdetails.asp?a=editdiscipline&sid=6627&paid=0&prid=1015>.
- B. Instructions for submitting questions and viewing Q&A and addenda under new AISD procurement procedures are provided on the project RFP (download at: <https://planroom.millerids.com/viewdetails.asp?a=editdiscipline&sid=6598&paid=0&prid=1015>)

If additional assistance is required with item #2, please contact Jennifer Nix at Austin ISD contract and procurement services (512-414-2241).

END.

