

ADDENDUM No. 4
Request for Competitive Sealed Proposals (CSP)
19CSP080 Renovations at Nelson Bus Terminal

January 25, 2019

Item 1: Questions and Answers

Item 1:

1. On page 1-101, general notes item no. I it talks about paint colors. In the pre/bid walk we were told that there was no paint in the scope of work. Please clarify .

Paint will only be applied to HVAC registers listed in mechanical drawings to be painted. They will be painted to match other registers.

2. On plan sheet M-5.5 key note 1 does that mean we notify AISD alarm people, or do we have to contract with someone?

If the building is already equipped with a fire alarm system then the duct smoke detector and relay need to interface with it. If it doesn't have a fire alarm system then the smoke detector and relay can be stand-alone and provided by the mechanical contractor

3. At the pre-bid the architect said he would send out an amendment with the cost of the building permit so the bidders could put it in our bid. I have seen it yet.

This information is not available.