



ADDENDUM No. 5
Request for Competitive Sealed Proposals (CSP)
20CSP106 Roof Improvements to Akins High School

April 8th, 2020

Received by bidder:

Date: _____

Name: _____

Signature: _____

Item 1: Updated Bid Delivery and Opening Instructions

Item 2: Questions and Answers

Item 1: Updated Bid Delivery and Opening Instructions

Due to COVID-19 precautions and to prevent the spread of COVID-19, and in an effort to provide ongoing support and services for Austin ISD, the District has decided to accept proposals for 20CSP106, Roof Improvements to Akins High School, via email to sara.hildebrandtgaspar@austinisd.org no later than Thursday, April 16th, 2020 at 2:00 p.m. CST. **All email submissions must contain the following subject line with no exceptions: “20CSP106 Submission - CONFIDENTIAL”.**

Proposals submitted via email should be not exceed 20MB. If you believe your attachment is more than 20MB, please zip the file or separate it into separate attachments.

If you have already submitted your hard proposal via mail or hand delivery, please also submit your proposal via email before due date and time so that we can facilitate review of proposals while we work remotely.

Original Bid Bonds should be scanned and present in the virtual submission. In addition, we are requiring the submission of the physical original bid bond via mail addressed as follows:

20CSP106 Bid Bond Submission
4000 S IH 35 Frontage Rd, Austin, TX 78704
Att: Sara Hildebrandt Gaspar

Proposals submitted via email must still be signed and all forms acknowledged. To ensure fairness and transparency and safeguard of proposal documents and content, no proposals received via email will be opened until after due date and time have passed. . **In order to accomplish this, all email submissions must contain the following subject line with no exceptions: “20CSP106 Submission - CONFIDENTIAL”.**

Construction Procurement will be hosting a virtual bid opening at 2:00PM on April 16th, 2020 via Zoom. To join this meeting, click the link below or copy and paste into your browser), and follow the instructions from Zoom using the meeting ID and password provided:

Join Zoom

Meeting <https://zoom.us/j/652317490?pwd=Wmo5U1VuNUNZYTVIK0Vlb1pEanFXZz09>

Meeting ID: 652 317 490

Password: 045940

Item 2: Questions and Answers

- Detail 10/R5 indicates to provide 18” min height from roof to bottom of roof top unit frame. Manufacturer only require 8” min flashing height. Is it acceptable to provide 8” or 12”?

A: Curbs shall be 18” tall.